

# Compliance Document

No. D 093811 0054 Rev. 00

**Holder of Certificate:** **INVT Solar Technology  
(ShenZhen) Co., Ltd.**  
6th Floor, Block A  
INVT Guangming Technology Building  
Kejie Fourth Road, Shutianpu Community, Matian  
Guangming District  
518000 Shenzhen  
PEOPLE'S REPUBLIC OF CHINA

**Product:** **Converter  
(Hybrid Solar Inverter)**

This Compliance document confirms the compliance with the listed standards on a voluntary basis. It refers only to the sample submitted for testing and certification and does not certify the quality or safety of the serial products. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 64290223076601

**Date,** 2022-07-06



( Billy Qiu )

# Compliance Document

No. D 093811 0054 Rev. 00

**Model(s):** **BD6KTR-RH3, BD8KTR-RH3, BD10KTR-RH3, BD12KTR-RH3, BD15KTR-RH3**

## Parameters:

Model	BD6KTR-RH3	BD8KTR-RH3	BD10KTR-RH3	BD12KTR-RH3	BD15KTR-RH3
Battery terminal parameters					
Rated battery DC voltage	200 Vd.c.	250 Vd.c.	300 Vd.c.	350 Vd.c.	400 Vd.c.
Battery DC voltage range	125-600 Vd.c.				
Max charging / discharging current	50 Ad.c.				
Battery type	Lithium-ion				
Maximum charge/discharge power	15000 W				
PV terminal parameters					
Max. Input Power	9000 W	12000 W	15000 W	18000 W	22500 W
Maximum DC input voltage	1000 Vd.c.				
MPPT Range	180~850 Vd.c.				
MPPT Range (full load)	250~850 Vd.c.	330~850 Vd.c.	430~850 Vd.c.	510~850 Vd.c.	620~850 Vd.c.
Max. Input Current	2*13 Ad.c.				
Isc PV	2*16 Ad.c.				2*25 Ad.c.
Grid terminal parameters					
Rated output Power	6000 W	8000 W	10000 W	12000 W	15000 W
Maximum continuous output apparent power	6600 VA	8800 VA	11000 VA	13200 VA	16500 VA
Max. AC output current	9.5 Aa.c.	12.7 Aa.c.	15.9 Aa.c.	19.1 Aa.c.	23.8 Aa.c.
Maximum continuous input apparent power	13200 VA	17600 VA	22000 VA	26400 VA	33000 VA
Max. AC input current	19 Aa.c.	25.5 Aa.c.	31.9 Aa.c.	38.2 Aa.c.	47.6 Aa.c.
Rated AC voltage	230/400 Va.c., 3W+N+PE				
Rated AC frequency	50 Hz				
Power factor	0.9lagging to 0.9leading				
Backup terminal parameters					
Rated apparent power	6000 VA	8000 VA	10000 VA	12000 VA	15000 VA
Maximum continuous output apparent power	6600 VA	8800 VA	11000 VA	13200 VA	16500 VA
Max. AC current	9.5 Aa.c.	12.7 Aa.c.	15.9 Aa.c.	19.1 Aa.c.	23.8 Aa.c.
Rated AC voltage	230/400 Va.c., 3W+N+PE				
Rated AC frequency	50Hz				



# Compliance Document

No. D 093811 0054 Rev. 00

**Tested  
according to:**

EN 50549-1:2019/AC:2019